

PORTABLE APPLIANCE TESTING CERTIFICATE

Certificate Number:

DETAILS OF THE CLIENT		DETAILS OF THE INSTALLATION ADDRESS	
Client and address:	So Soft Play , Whydown Farm , Crazy Lane Sedlescombe , East Sussex	Installation address:	So Soft Play , Whydown Farm , Crazy Lane Sedlescombe , East Sussex
	Postcode: TN33 OQT		Postcode: TN33 OQT

DETAILS OF THE CONTRACTOR RESPONSIBLE FOR THE TESTING			
Trading Title: SGR Pattesting			
Address:	9 Amherst Close Hastings East Sussex	Registration Number:	NA
		Test Equipment Used:	Kewtech Smart Pat Plus
		Telephone Number:	07703533132
		Serial Number:	E0081732
	Postcode: TN34 1TY		
For the inspection and testing of the electrical equipment:			
Name:	Lee Vater	Position:	Electrician
		Signature:	
		Date:	01/12/2025

APPLIANCE DETAILS AND TEST RESULTS																		
Appliance ID	Test Date	Description	Location	RP	Retest Date	Fuse Size	Class	Visual	Polarity	Earth Continuity (Ohms)	Insulation (M Ohms)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Flash (mA)	Load (kVA)	Clamp (mA)	Status
Site: so soft play																		
AP0001	01/12/25	speaker	container	12	01/12/26	3A	2	P	P	S > 200	P	S	S	0.05	P	S	S	S Pass
AP0002	01/12/25	speaker	container	12	01/12/26	3A	2	P	P	S > 200	P	S	S	0.05	P	S	S	S Pass
AP0003	01/12/25	speaker	container	12	01/12/26	3A	2	P	P	S > 200	P	S	S	0.04	P	S	S	S Pass
AP0004	01/12/25	smoke machine	container	12	01/12/26	13A	2	P	P	S > 200	P	S	S	0.06	P	S	S	S Pass
AP0005	01/12/25	plug in lights	container	12	01/12/26	3A	2	P	P	S > 200	P	S	S	0.04	P	S	S	S Pass
AP0006	01/12/25	plug in lights	container	12	01/12/26	3A	2	P	P	S > 200	P	S	S	0.04	P	S	S	S Pass
AP0007	01/12/25	4 way extension	container	12	01/12/26	13A	N/A	P	P	0.81	P > 200	P	S	S	S	S	S	S Pass
AP0008	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.30	P > 200	P	S	S	0.17	P	S	S Pass
AP0009	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.07	P > 200	P	S	S	0.19	P	S	S Pass
Key: P=Pass F=Fail S=Skip (or test not applicable)																		

Appliance Details and Test Results																			
Appliance ID	Test Date	Description	Location	RP	Retest Date	Fuse Size	Class	Visual	Polarity	Earth Continuity (Ohms)	Insulation (M Ohms)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Flash (mA)	Load (kVA)	Clamp (mA)		Status
Site: so soft play (Continued)																			
AP0010	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.08 P > 200 P	P	S	S	0.17 P	S	S	S		Pass
AP0011	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.23 P > 200 P	P	S	S	0.20 P	S	S	S		Pass
AP0012	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.18 P > 200 P	P	S	S	0.09 P	S	S	S		Pass
AP0013	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.09 P > 200 P	P	S	S	0.20 P	S	S	S		Pass
AP0014	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.08 P > 200 P	P	S	S	0.21 P	S	S	S		Pass
AP0015	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.19 P > 200 P	P	S	S	0.28 P	S	S	S		Pass
AP0016	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.10 P 10.44 P	P	S	S	0.22 P	S	S	S		Pass
AP0017	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.19 P > 200 P	P	S	S	0.19 P	S	S	S		Pass
AP0018	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.18 P > 200 P	P	S	S	0.17 P	S	S	S		Pass
AP0019	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.27 P > 200 P	P	S	S	0.08 P	S	S	S		Pass
AP0020	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.08 P > 200 P	P	S	S	0.19 P	S	S	S		Pass
AP0021	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.12 P > 200 P	P	S	S	0.08 P	S	S	S		Pass
AP0022	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.17 P > 200 P	P	S	S	0.08 P	S	S	S		Pass
AP0023	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.25 P > 200 P	P	S	S	0.09 P	S	S	S		Pass
AP0024	01/12/25	fan	container	12	01/12/26	13A	1	P	P	0.16 P > 200 P	P	S	S	0.17 P	S	S	S		Pass
AP0025	01/12/25	1 way commando plug	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S		Pass
AP0026	01/12/25	1 way commando plug	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S		Pass
AP0027	01/12/25	1 way commando plug	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S		Pass
AP0028	01/12/25	1 way commando plug	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S		Pass
AP0029	01/12/25	1 way commando plug	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S		Pass
Key: P=Pass F=Fail S=Skip (or test not applicable)																			

APPLIANCE DETAILS AND TEST RESULTS

Appliance ID	Test Date	Description	Location	RP	Retest Date	Fuse Size	Class	Visual	Polarity	Earth Continuity (Ohms)	Insulation (M Ohms)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Flash (mA)	Load (kVA)	Clamp (mA)	Status
Site: so soft play (Continued)																		
AP0030	01/12/25	1 way commando plug	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S	Pass
AP0031	01/12/25	4 way extension	container	12	01/12/26	13A	N/A	P	P	0.60	P > 200	P	S	S	S	S	S	Pass
AP0032	01/12/25	1 way extension	container	12	01/12/26		N/A	P	P	S	S	S	S	S	S	S	S	Pass
AP0033	01/12/25	4 way extension	container	12	01/12/26	13A	N/A	P	P	0.08	P > 200	P	S	S	S	S	S	Pass
AP0034	01/12/25	1 way extension	container	12	01/12/26	13A	N/A	P	P	0.04	P > 200	P	S	S	S	S	S	Pass
AP0035	01/12/25	4 way extension	container	12	01/12/26	13A	N/A	P	P	0.54	P > 200	P	S	S	S	S	S	Pass
Total Appliances for Report: 35																		

Key: P=Pass F=Fail S=Skip (or test not applicable)